



545 E Algonquin Road, Suite H
Arlington Heights, IL 60005

Telephone: 847-439-5667
www.intertek.com

PUBLIC NOTICE

**Intertek Warns of Counterfeit
Authorization to Mark (ATM) Certificate for
Yekalon Industry Metal Fire Doors**

Published: September 28, 2016

The following is a notification from Intertek that a counterfeit cWHus Authoriation to Mark (ATM) Certificate for Yekalon Industry Metal Fire Doors has been found in the marketplace misrepresenting the products as certified for the United States and Canada. The products have not been evaluated by Intertek and it is not known if they comply with any safety requirements.

Product Description	<i>Metal Fire Doors</i>
Manufacturer/Brand	<i>Yekalon Industry Inc.</i>
Identification	<i>cWHus Authorization to Mark with Control Number 231793 referencing Report AU10124008-1</i>
Reported Hazards	<i>Unknown</i>
Sold at	<i>Unknown</i>
What To Do	<i>Consumers should immediately stop using the product and contact Yekalon Industry Inc. or the retailer from which it was purchased</i>

Counterfeit Certificate Image

AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report(s). This authorization also applies to the Multiple Listee model(s) identified on the correlation page of the Listing Report. This document is the property of Intertek Testing Services and is not transferable. The Certification Mark(s) may be applied only at the location of the Party Authorized to Apply Mark.

Applicant:	Yekalon Industry, Inc. 3rd floor, Flat A, Jinxu Building, Wanjin Middle Road, Shenzhen city, P.R. China, 518003
Country:	China
Contact:	Stanly Lin
Phone:	86-755-2516-0826
Fax:	86-755-2541-9568
Email:	info@yekalon.com
Party Authorized to Apply Mark:	See following page(s)
Evaluation Center:	Intertek (Shanghai)
Control/Client Number: 231793	Authorized By: Bob Davison, Director, Certification Services

Intertek Testing Services NA, Inc.
8431 Murphy Drive, Middleton, WI 53062 USA
Phone 608-824-7440 Fax 608-831-9279

This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow-up Services are for the purpose of ensuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Testing Standard(s):	ULBC 7-2 (1997); CAN4 S104 (1985); NFPA 252 (2008); UL 10(c) (2009); UL 10(b) (2009); CAN / ULCS 104 (2010)
Product:	metal fire doors

ATM for Report AU10124008-1

ATM Issue Date: 02/03/2012