

STANDARD INFORMATION

Standard: UL 1286

Standard ID: Office Furnishings [UL 1286:2022 Ed.6+R:21Mar2024]

Previous Standard ID: Office Furnishings [UL 1286:2022 Ed.6+R:31Aug2023]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **June 21, 2026**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes: Addition of Requirements for Tamper-Resistant Receptacles to Harmonize with NEC Article 406.12. Specific details of new/revised requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined-out below.</i>
13	Info	Electrical Connecting Assemblies
13.4	Info	Convenience outlets
13.4.1	Info	Receptacles
		<i>New clause added;</i>
13.4.1.10		All non-locking type convenience receptacles (ANSI/NEMA 5-15R or 5-20R) used in areas identified in Article 406.12 of the National Electrical Code, NFPA 70, shall be Tamper-Resistant type.
		Exception No. 1: This requirement does not apply when receptacles are located more than 5-1/2 feet (1.7 m) above the floor.
		Exception No. 2: This requirement does not apply when receptacles are part of a luminaire or appliance.