

STANDARD INFORMATION

Standard: UL 1565 / CSA C22.2 No. 18.5

Standard ID:

Positioning Devices [UL 1565:2022 Ed.6+R:14Jun2024]

Positioning Devices [CSA C22.2#18.5:2022 Ed.3+U1]

Previous Standard ID:

Positioning Devices [UL 1565:2022 Ed.6]

Positioning Devices [CSA C22.2#18.5:2022 Ed.3]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **June 14, 2026**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes: Intended Use "Within an Enclosure" Related to Wiring Ducts. Specific details of new/updated requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined-out below.</i>
14	Info	Classification Intended use according to:
14.6		a) Product intended for use as a complete system – Indoor use; or b) Component intended for use in a complete product or system – Indoor use; or. c) <u>Wiring duct – intended for use within an enclosure as a component in a complete product or system – Indoor Use.</u>
21	Info	Specific Markings Based on Classification <i>New clause added;</i>
21.7A		A wiring duct classified according to 14.6(c) shall be marked “For use within equipment”, or an equivalent wording or notation that indicates this specific use.