

## STANDARD INFORMATION

**Standard:** UL 2238

**Standard ID:** Cable Assemblies and Fittings for Industrial Control and Signal Distribution [UL 2238:2018 Ed.3+R:03Jan2024]

**Previous Standard ID:** Cable Assemblies and Fittings for Industrial Control and Signal Distribution [UL 2238:2018 Ed.3+R:11Aug2023]

## EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

**Effective Date:** **April 3, 2026**

## IMPACT, OVERVIEW, AND ACTION REQUIRED

**Impact Statement:** Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

**Overview of Changes:** Marking on body not for small size product. Specific details of new/revise requirements are found in table below.

***Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.***



## STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown <del>lined-out</del> below.</i>
	Info	<b>MARKINGS</b>
40	Info	<b>Details</b>
40.1	Info	<b>General</b>
40.1.6		A device shall be marked with the following or with an equivalent statement, "Not for current interrupting" or "For disconnecting use only." <u>This statement shall appear on the device or on a flag label wrapped around the cord as close to the fitting as possible or on the smallest unit container or package. When a flag label is used it shall comply with 37.10.</u>